



Report #: 5500198

Lab Certification No. 11676 DOH NY

Page 1 of 4

Date Collected: 5/ 4/00

Date Received: 5/ 5/00

Date Analyzed: 5/ 5/00

Customer: Same as Client

Client : Keith A. Oberg

Sample

Location: PO Box 1875
Brackney, PA 18812

Matrix: ~~Drinking~~ Lake Water

Purchase Order #:

Sample Description This sample taken by Keith at 08:00 AM on 5/4/00. Point of Collection: Kitchen. *Sink. Supply from pump in lake*

*** Comprehensive Scan Report ***

Parameter(s) tested meets EPA primary (health related) and secondary (aesthetic) limits for drinking water

PARAMETER	RESULTS	Maximum Contamination Limit	DESCRIPTION	Minimum Detecto Level
Total Coliform <i>-</i>	Absent	Present	Animal/Vegetational Bacteria (Health Related)	0/100
Fecal/E. Coli <i>-</i>	Absent	Present	Animal Bacteria (Health Related)	0/100
Sodium	4.7	250.0 mg/L	20.0 mg/L is Mass. DEP Guideline	0.05
Potassium	0.73	No Limit (mg/L)	A Component of Salt (Aesthetic)	0.02
Copper	0.14	1.30 mg/L	Indicates Plumbing Corrosion (Aesthetic)	0.006
Iron	0.02	0.30 mg/L	Brown Stains, Bitter Taste (Aesthetic)	0.003
Manganese	0.02	0.05 mg/L	May Cause Laundry Staining (Aesthetic)	0.001
Magnesium	1.2	No Limit (mg/L)	A Component of Hardness	0.005
Calcium	5.4	No Limit (mg/L)	A Component of Hardness	0.008
Arsenic	Not Detected	0.05 mg/L	A Toxic Metal (Health Related)	0.006
Lead	Not Detected	0.015 mg/L	A Toxic Metal (Health Related)	0.005
+ pH	7.01	6.5 - 8.5 SU	Acidic/Basic Determination (Aesthetic)	0 - 14
Turbidity <i>-</i>	0.32	No Limit (N.T.U.)	Presence of Particles	0.10
Color	Not Detected	15.0 C.U.	Clarity (0) Discoloration (15) (Aesthetic)	1.0
Odor	Not Detected	3.0 T.O.N.	Odor due to Contamination (Aesthetic)	0.50
Conductivity	121.0	700 umhos	Electrical Resistance (umhos/cm)	0.10
T.D.S.	72.6	500 mg/L	Total Dissolved Minerals Present (Aesthetic)	1.0
Sediment <i>-</i>	Absent	Present	Undissolved Solid	Pres/Abs
Alkalinity	40.0	No Limit (mg/L)	Ability to Neutralize Acid (Aesthetic)	1.0
Chlorine	Not Detected	No Limit (mg/L)	A Disinfectant	0.01
Chloride	7.4	250 mg/L	A Component of Salt (Aesthetic)	1.0
Hardness	18.4	No Limit (mg/L)	0 - 75 is Considered Soft	1.0
Nitrate	0.20	10.0 mg/L	Indicator of Biological Waste (Health Related)	0.10
Nitrite	Not Detected	1.0 mg/L	Indicator of Waste (Health Related)	0.01
Ammonia	Not Detected	No Limit (mg/L)	Indicator of Waste	0.01
Sulfate	8.9	250 mg/L	A Mineral, Can Cause Odor	1.0
Radon in Water	819	10,000 pCi/L	Massachusetts D.E.P. Proposed Guideline	90

Charcoal filter

*** = Outside of Recommended Limits**

Visit us on the Web

The integrity of the sample and results are dependent on the quality of sampling. The results apply only to the actual sample tested. Some methods may be modified to accommodate transportation. AAA Water Testing shall be held harmless from any liability arising out of the use of such results.

Date Collected: 5/ 4/00
 Date Received: 5/ 5/00
 Date Analyzed: 5/ 5/00

Customer: Same as Client

Client : Keith A. Oberg

Sample

Location: PO Box 1875
 Brackney, PA 18812

Matrix: Drinking Water

Purchase Order #:

Sample Description This sample taken by Keith at 08:00 AM on 5/4/00. Point of Collection: Kitchen.

* Comprehensive Scan Report *

Parameter(s) tested meets EPA primary (health related) and secondary (aesthetic) limits for drinking water

ANALYTE	RESULTS		Maximum Contamination Limit	Minimum Detection Level
	(ug/L)	(ug/L)	(ug/L)	(ug/L)
Benzene:	Not Detected	5.0	5.0	0.5
Bromobenzene:	Not Detected			0.5
Bromochloromethane:	Not Detected			0.5
Bromodichloromethane:	Not Detected			0.5
Bromoform:	Not Detected			0.5
Bromomethane:	Not Detected			0.5
n-Butylbenzene:	Not Detected			0.5
sec-Butylbenzene:	Not Detected			0.5
tert-Butylbenzene:	Not Detected			0.5
Carbon-Tetrachloride:	Not Detected	5.0	5.0	0.5
Chlorodibromomethane:	Not Detected			0.5
Chloroethane:	Not Detected			0.5
Chloroform:	Not Detected			0.5
Chloromethane:	Not Detected			0.5
1,2-Chlorotoluene:	Not Detected			0.5
1,4-Chlorotoluene:	Not Detected			0.5
1,2-Dibromo-3-chloropropane:	Not Detected			0.5
Dibromomethane:	Not Detected			0.5
1,2-Dibromoethane:	Not Detected			0.5
1,3-Dichlorobenzene:	Not Detected			0.5
1,2-Dichlorobenzene:	Not Detected	600.0	600.0	0.5
1,4-Dichlorobenzene:	Not Detected	5.0	5.0	0.5
Dichloromethane:	Not Detected	5.0	5.0	0.5
Dichlorodifluoromethane:	Not Detected			0.5

*** = Outside of Recommended Limits**

Visit us on the Web

The integrity of the sample and results are dependent on the quality of sampling. The results apply only to the actual sample tested. Some methods may be modified to accommodate transportation. AAA Water Testing shall be held harmless from any liability arising out of the use of such results.

Date Collected: 5/ 4/00

Date Received: 5/ 5/00

Date Analyzed: 5/ 5/00

Customer: Same as Client

Client : Keith A. Oberg

Sample

Location: PO Box 1875
Brackney, PA 18812

Matrix: Drinking Water

Purchase Order #:

Sample Description This sample taken by Keith at 08:00 AM on 5/4/00. Point of Collection: Kitchen.

* Comprehensive Scan Report *

Parameter(s) tested meets EPA primary (health related) and secondary (aesthetic) limits for drinking water

ANALYTE	RESULTS (ug/L)	Maximum Contamination Limit (ug/L)	Minimum Detection Level (ug/L)
1,1-Dichloroethane:	Not Detected		0.5
1,2-Dichloroethane:	Not Detected	5.0	0.5
1,1-Dichloroethylene:	Not Detected	7.0	0.5
cis-1,2-Dichloroethene:	Not Detected	70.0	0.5
trans-1,2-Dichloroethene:	Not Detected	100.0	0.5
1,2-Dichloropropane:	Not Detected	5.0	0.5
1,3-Dichloropropane:	Not Detected		0.5
2,2 Dichloropropane:	Not Detected		0.5
1,1 Dichloropropene:	Not Detected		0.5
1,3-Dichloropropene:	Not Detected		0.5
trans-1,3-Dichloropropene:	Not Detected		0.5
Ethylbenzene:	Not Detected	700.0	0.5
Fluorotrichloromethane:	Not Detected		0.5
Hexachlorobutadiene:	Not Detected		0.5
Isopropylbenzene:	Not Detected		0.5
1,4-Isopropyltoluene:	Not Detected		0.5
Methyl-t-Butyl Ether (MTBE):	Not Detected		0.5
Monochlorobenzene:	Not Detected	100.0	0.5
Napthalene:	Not Detected		0.5
n-Propylbenzene:	Not Detected		0.5
Styrene:	Not Detected	100.0	0.5
1,1,1,2-Tetrachloroethane:	Not Detected		0.5

*** = Outside of Recommended Limits**

Visit us on the Web

The integrity of the sample and results are dependent on the quality of sampling. The results apply only to the actual sample tested. Some methods may be modified to accommodate transportation. AAA Water Testing shall be held harmless from any liability arising out of the use of such results.

Date Collected: 5/ 4/00
 Date Received: 5/ 5/00
 Date Analyzed: 5/ 5/00

Customer: Same as Client

Client : Keith A. Oberg

Sample

Location: PO Box 1875
 Brackney, PA 18812

Matrix: Drinking Water

Purchase Order #:

Sample Description This sample taken by Keith at 08:00 AM on 5/4/00. Point of Collection: Kitchen.

* Comprehensive Scan Report *

Parameter(s) tested meets EPA primary (health related) and secondary (aesthetic) limits for drinking water

ANALYTE	RESULTS	Maximum Contamination Limit	Minimum Detection Level
	(ug/L)	(ug/L)	(ug/L)
1,1,2,2-Tetrachloroethane:	Not Detected		0.5
Tetrachloroethylene:	Not Detected	5.0	0.5
Toluene:	Not Detected	1000.0	0.5
1,2,3-Trichlorobenzene:	Not Detected		0.5
1,2,4-Trichlorobenzene:	Not Detected	70.0	0.5
1,1,1-Trichloroethane:	Not Detected	200.0	0.5
1,1,2-Trichloroethane:	Not Detected	5.0	0.5
Trichloroethylene (TCE)	Not Detected	5.0	0.5
1,2,3-Trichloropropane:	Not Detected		0.5
1,2,4-Trimethylbenzene:	Not Detected		0.5
1,3,5-Trimethylbenzene:	Not Detected		0.5
Vinyl Chloride:	Not Detected	2.0	0.5
o-Xylene:	Not Detected	Total Xylenes 10,000	0.5
m + p-Xylenes:	Not Detected	Total Xylenes 10,000	0.5

*** = Outside of Recommended Limits**

Visit us on the Web

The integrity of the sample and results are dependent on the quality of sampling. The results apply only to the actual sample tested. Some methods may be modified to accommodate transportation. AAA Water Testing shall be held harmless from any liability arising out of the use of such results.